

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

1155

WELL PERMIT NUMBER 280958
DIV. 1 WD 8 DES. BASIN MD

APPLICANT

FREDERICK & RACHEL AYARS
38 PAWNEE CREEK DRIVE
LAKE GEORGE, CO 80827-

(719) 440-9557

Lot: 2 Block: 4 Filing: 4 Subdiv: INDIAN CREEK

APPROVED WELL LOCATION

TELLER COUNTY
SE 1/4 SE 1/4 Section 23
Township 12 S Range 71 W Sixth P.M.

DISTANCES FROM SECTION LINES

Ft. from Section Line
Ft. from Section Line

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: Northing:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a residential site of 5.50 acre(s) described as Lots 2 & 3, Block 4, Filing 4, Indian Creek Subdivision, Teller County.
- 4) Approved for the relocation of an existing unpermitted well. The old unpermitted well must be plugged in accordance with Rule 16 of the Water Well Construction Rules within ninety (90) days of completion of the new well. The enclosed Well Abandonment Report form must be completed and submitted to affirm that the old well was plugged.
- 5) The use of ground water from this well is limited to ordinary household purposes inside one single family dwelling. The ground water shall not be used for irrigation or other purposes.
- 6) The pumping rate of this well shall not exceed 15 GPM.
- 7) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 8) Pursuant to Rule 6.2.3 of the Water Well Construction Rules, the well construction contractor shall submit the as-built well location on work reports required by Rule 17.3 within 60 days of completion of the well. The measured location must be accurate to 200 feet of the actual location. The location information must include either the 1/4, 1/4, Section, Township, Range, and distances from section lines, or a GPS location pursuant to the Division of Water Resources' guidelines.

NOTICE: This permit has been approved for the replacement of an existing unpermitted well to be located on Lots 2 & 3, Block 4, Filing 4 of the Indian Creek Subdivision (the application originally specified Lot 4). You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Test Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. An extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: <http://www.water.state.co.us/pubs/forms.asp>

Expiration Date Extended to June 17, 2012 svj 6-1-11

JD 6-17-09

APPROVED
JD2

Dirk Wolfe

State Engineer

Jeff Dea

By

Receipt No. 3640404

DATE ISSUED 06-17-2009

EXPIRATION DATE 06-17-2011