

OFFICE OF THE STATE ENGINEER  
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203  
(303) 866-3581

WELL PERMIT NUMBER	<b>176139</b>
DIV. 1	CNTY. 35 WD 3 DES. BASIN MD

APPLICANT

MARION MONROE  
5445 CO RD 68C  
RED FEATHER LKS CO 80545

(303)881-2456

APPROVED WELL LOCATION  
LARIMER COUNTY

NE 1/4 NW 1/4 Section 20  
Twp 9 N RANGE 71 W 6th P.M.

DISTANCES FROM SECTION LINES

500 Ft. from North Section Line  
2250 Ft. from West Section Line

**PERMIT TO CONSTRUCT A WELL**

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT  
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of the permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction and Pump Installation Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 17.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 35.66 acres described as tract 15, being more particularly described on the attached exhibit "A".
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside 3 single family dwellings, the irrigation of not more than one (1) acre of home gardens and lawns and the watering of domestic animals.
- 5) The maximum pumping rate shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) This well shall be constructed not more than 200 feet from the location specified on this permit.

*M.M. 2-9-14*

APPROVED  
MAM

*Hal D. Simpson*  
\_\_\_\_\_  
State Engineer

*M. A. Malley*  
\_\_\_\_\_  
By

Receipt No. 0364175

DATE ISSUED FEB 10 1994

EXPIRATION DATE FEB 10 1996