

USE TYPEWRITER OR BALL POINT PEN

State of Idaho Department of Water Resources

RECEIVED

WELL DRILLER'S REPORT

NOV 16 1978

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

Department of Water Resources


1. WELL OWNER
Name Mr. Gene Johnson
Address Cottonwood, Idaho
Owner's Permit No. _____

2. NATURE OF WORK
 New well Deepened Replacement
 Abandoned (describe method of abandoning)

3. PROPOSED USE
 Domestic Irrigation Test Other (specify type)
 Municipal Industrial Stock Waste Disposal or Injection

4. METHOD DRILLED
 Cable Rotary Dug Other

5. WELL CONSTRUCTION
Diameter of hole 6 inches Total depth 60 feet
Casing schedule: Steel Concrete
Thickness .250 inches Diameter 6 5/8 inches From 2 feet To 30 feet
Was casing drive shoe used? Yes No
Was a packer or seal used? Yes No
Perforated? Yes No
How perforated? Factory Knife Torch
Size of perforation _____ inches by _____ inches
Number _____ From _____ To _____
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet
Well screen installed? Yes No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Gravel packed? Yes No Size of gravel _____
Placed from _____ feet to _____ feet
Surface seal depth 29' Material used in seal Cement grout
 Pudding clay Well cuttings
Sealing procedure used Slurry pit Temporary surface casing
 Overbore to seal depth

6. LOCATION OF WELL
Sketch map location must agree with written location. 79

Subdivision Name None
Lot No. Unk. Block No. _____
County Idaho
NW 1/4 SW 1/4 Sec. 30 T. 30N N/S, R. 1E E/W

7. WATER LEVEL
Northern District Office
Static water level 20 feet below land surface
Flowing? Yes No G.P.M. flow _____
Temperature Unk.° F. Quality Good
Artesian closed-in pressure _____ p.s.i.
Controlled by Valve Cap Plug

8. WELL TEST DATA
 Pump Bailor Other (air)
Discharge G.P.M. Draw Down Hours Pumped
10 Unk. 2

9. LITHOLOGIC LOG 87545
Hole Diam. Depth Material Water Yes No
6 0 8 Overburden
8 30 Boulders, cobbles
30 60 Gray basalt (hard)
Hit water at 35 feet
10 Gallons per minute.

10. Work started July 8, 78 finished July 8, 78

11. DRILLERS CERTIFICATION
Firm Name Uhlenkott Well Drilling Firm No. 125
Address Fenn, Idaho Date Nov. 11, 78
Signed by (Firm Official) Ray Uhlenkott
and Richard P. Uhlenkott
(Operator)

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE COPY TO THE DEPARTMENT

RECORDED