

Call 0722

STATE ELECTRICAL BOARD
INSPECTION REPORT / CORRECTION NOTICE

Date Rec. 2 April 07 PERMIT # 612215
970-581-4355

Contractor/Home Owner: Legacy Elect. Inc.
970-581-4355

Address: 6215 Mill Creek Rd.
567-4965

Mill Creek
TYPE OF INSPECTION:

Partial ☒ Rough in ☒ Underground ☐ Final ☐

ACTION: Accepted ☒ Rejected ☐ Remarks ☐

REINSPECTION FEE

Comments or Corrections: Wire in ground
not flush with ground.

Inspector's Name Steve J. DeBels

Phone # 970 223 9835 Date 3 April 07