



Nebraska Department of Environment and Energy
 Water Quality Division
 Onsite Wastewater Treatment Program
 (402) 471-4285
<http://dee.ne.gov>

Office Use Only
NDEE File

Onsite Wastewater Treatment System
 Registration Receipt

WESTON SCHMIDT
 804 FISH CREEK AVE
 SCOTIA, NE 68875

COPY TO:
 TREVOR KNOPIK
 1113 WILLARD AVE
 GENOA, NE 68640

RE: System Number: TS41542
 NDEEID #: 121659

The following Onsite Wastewater Treatment System has been registered with the Nebraska Department of Environment and Energy as required by *Title 124 – Rules and Regulations for the Design, Operation and Maintenance of Onsite Wastewater Treatment System*.

Please note that this registration simply acknowledges receipt by the NDEE of a completed registration form and registration fee (and late fee if applicable), and is not an acknowledgment by the Department that the actual installation complies with the design, setback or other requirements prescribed in regulation.

SYSTEM OWNER WESTON SCHMIDT 804 FISH CREEK AVE SCOTIA, NE 68875	SYSTEM LOCATION
SYSTEM LEGAL DESCRIPTION	
SYSTEM MAPPING COORDINATES Latitude: 41 28 58 Longitude: -98 37 3.	

SYSTEM REGISTERED BY TREVOR KNOPIK	CERTIFICATE OR LICENSE NUMBER OWT Systems Professional # 1863		
REGISTRATION REASON NEW SYSTEM	<table> <tr> <td>REGISTERED 8/30/2024</td><td>CONSTRUCTION COMPLETED 8/13/2024</td></tr> </table>	REGISTERED 8/30/2024	CONSTRUCTION COMPLETED 8/13/2024
REGISTERED 8/30/2024	CONSTRUCTION COMPLETED 8/13/2024		

DETAILS ON FILE WITH NDEE:

Treatment Type = Septic System	Construction / Operating Permit:
Design Flow: 500 gpd	Soil Absorption System: Trench
Depth to Groundwater: 140 ft	Effective Bottom Area: 1035.0 sq ft
Percolation Rate: 25.0 min/in	Number of Trenches: 2
Liner: N	Trench Width: 36.0
Septic Tank Capacity: 1530 gal	Total Trench Length: 230.0 ft
Garbage Grinder: N	Treatment Media:
Large Capacity Tub: N	Distribution System: BUNDLED POLYSTYRENE WITHOUT FILTER

If any of this information is incorrect, please contact the **NDEE Onsite Wastewater Treatment Program** at **402-471-4285** with the correct information.