



**ORIGINAL PERMIT APPLICANT(S)**

KEVIN MILLER

**APPROVED WELL LOCATION**

Water Division: 1 Water District: 3  
Designated Basin: N/A  
Management District: N/A  
County: WELD  
Parcel Name: FFD24-0012

**AUTHORIZED AGENT**

AGPROFESSIONALS (DUTROW, HANNAH)

Lot: B Block: Filing:

Physical Address: TBD GREELEY, CO 80631

EH 1/2 SW 1/4 Section 23 Township 6.0 N Range 66.0 W Sixth P.M.

Well to be constructed on specified tract of land

**PERMIT TO CONSTRUCT A NEW WELL**

**ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT  
CONDITIONS OF APPROVAL**

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) **CONDITION REVOKED ON 07/17/2024 REPLACED BY CONDITION #4.**  
Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 70.20 acres described as Lot B, Recorded Exemption No. 0805-23-03 RECX18-0059, Weld County.
- 4) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 65.59 acres described as lot B, Family Farm Division case no. FFD24-0012, Weld County.
- 5) The use of groundwater from this well is limited to fire protection, ordinary household purposes inside not more than three (3) single family dwellings, the watering of poultry, domestic animals and livestock on a farm or ranch and the irrigation of not more than one (1) acre of home gardens and lawns.
- 6) The pumping rate of this well shall not exceed 15 GPM.
- 7) The return flow from the use of this well must be through an individual wastewater disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 8) Pursuant to Rule 6.2.3 of the Water Well Construction Rules, the well construction contractor shall submit the as-built well location on work reports required by Rule 17.1 within 60 days of completion of the well. The measured location must be accurate to 200 feet of the actual location. The location information must include a GPS location (UTM coordinates) pursuant to the Division of Water Resources' guidelines.
- 9) **ADVANCE NOTICE REQUIRED** - Pursuant to Construction Rule 6.2.2.1 (2 CCR 402-2), licensed or private drillers and pump installers must provide advance notification (by 11:59 pm the day before) to the State Engineer prior to each of the following for this well: the start of well construction, the initial installation of the first permanent pump, and the initial installation of a cistern connected to the water well supply system. Any change in the date of construction/installation must be re-noticed prior to the activity (by 11:59 pm the day before). Information regarding the notification process and a link to the electronic notification form can be found on the Division of Water Resources website at [dwr.colorado.gov](http://dwr.colorado.gov)

**CONDITION REVOKED ON 02/06/2024 REPLACED BY CONDITION #10.**

NOTE: This well may be located in an area where one or more confining layers may be penetrated during drilling. A hydrogeologic aquifer evaluation has not been completed for this well permit. In accordance with Rule 10.1.2 (Well Construction Rules, 2 CCR 402-2), all persons authorized to construct wells must investigate and become familiar with the geology of potential aquifers, confining layers, anticipated water quality problems, and known contaminated water-bearing zones that may be encountered in the area of the proposed drilling activity. The Applicant or Driller may request a hydrogeologic aquifer review by submitting an AskDWR to the "Hydrogeology Section" Topic.

NOTE: A hydrogeologic aquifer evaluation has been completed for this permit and the details of the evaluation can be viewed in the hydrogeologic aquifer evaluation imaged document located in the well permit file.

NOTE: The alluvial aquifer extends from surface to approximately 30 feet below ground surface. Wells completed in the alluvial aquifer must be constructed in accordance with Well Construction Rule 10.4.7 (2 CCR 402-2) for a Type 3 aquifer.

NOTE: The Laramie-Fox Hills aquifer extends from approximately 30-375 feet below ground surface. Wells completed in the Laramie-Fox Hills aquifer must be constructed with solid steel casing and grouted in accordance with Well Construction Rule 10.4.8 (2 CCR 402-2).

NOTE: The Upper Pierre Aquifer extends from approximately 460-1435 feet below ground surface, which is a Type 1 aquifer overlain by a single confining unit. Wells completed in a Type I aquifer penetrating only one confining layer must be constructed in accordance with Well Construction Rule 10.4.5.1 (2 CCR 402-2).

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Yield Estimate Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. An extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: [dwr.colorado.gov](http://dwr.colorado.gov)



Date Issued: 12/28/2022

Issued By BRIANNA KRAUSER

Expiration Date: 12/28/2024

07-17-2024 PERMIT AMENDMENT (CONDITIONS)

02-06-2024 PERMIT AMENDMENT (CONDITIONS)