

APPLICATION AND PERMIT FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

ENTERED

LARIMER COUNTY HEALTH DEPARTMENT

363 Jefferson St., Fort Collins, CO 80524

221-2100 EXT. 596

MICROFILMED
2168



0426000016

26
2/3 T 4 R 70

Mail to:
P.O. 334, Buttrick

1. _____ 1/4, _____ 1/4, _____ 1/4, S 2/3 T 4 R 70
2. Subdivision _____
3. Lot _____ Block _____ Filing _____ Zoned _____
4. New Repair 320 Del Monte Rd
5. Address/Location 749 County Rd. 27E, Buttrick, Co
6. Owner of Record Thomas & Linnæa Sahl Address Same Ph. 532-3117
7. Agent _____ Address _____ Ph. _____
8. System Contractor _____ Address _____ Ph. _____
9. Building Type Residence Basement Bathroom No Design Capacity 3 Bdrms
10. Lot Size 35A Slope 5% Perc. Rate/H.C. 34 mpi Depth to Bedrock > 8'
11. Depth to water Table > 8' Potable Water Supply Well Aquifer _____
12. Water District None
13. Sanitation District _____
14. Nearest Location of Public Sewer To Building _____
15. Exhibits check: Plot Plan _____ Eng. Geol. Report _____ Engineers Design _____
16. Owner/Agent Signature Linnæa S. Sahl Date 7-7-82
17. Engineer Signature _____ P.E. Reg. # _____ Date _____
18. Fee of \$ 150.00 payable at time Permit is issued. # 859
19. Plot plan on reverse of this form.

Permission is hereby granted to the owner or his agent to perform the work indicated below in accordance with the Larimer County Individual Sewage Disposal Regulations and is conditional upon the final installation approval of the Larimer County Health Department. This permit is to remain in full force for the duration of the Larimer County Building Permit, or 120 days after its issuance, where applicable, providing it is not revoked for non-compliance. The issuance of this permit does not constitute assumption by the Department or its employees of liability for the failure or inadequacy of the sewage disposal system.

20. Type and design of System Standard Design system. 1000 gal septic tank followed by 1,320 sq ft. of absorption field. Maintain 100 ft distance between field and well.
(Design Code 1)

21. Maintenance Schedule pump tank every 3-4 years

22. Please notify the department 24 hours in advance of backfilling to obtain final inspection for issuance of "Occupancy Certificate".

Approval Signature	Date	Approval Signature	Date
23. Site Inspection: <u>Jaswanth</u>	<u>7/9/82</u>	Sanitation District: _____	_____
24. Preliminary: <u>Jaswanth</u> R.P.S.	<u>7/9/82</u>	Occupancy Permit Signed: <u>M. Zimman</u>	<u>11-9-87</u>
25. Final Inspection: <u>JRC</u> R.P.S.	<u>5/2-84</u>	And Transmitted By: _____	_____

11
N

Bonne D'Ar

WATER SLIDE
+ TUNNEL

CR 27E

Temporary
Trailer



54'



1000 gal

120'



60'

22'

60
220
120
120
1300